



**DRIVEWAY IN SIDEWALK**

**NOTES:**

1. Curb and Apron to be poured separately. Monolithic curb and apron is not allowed.
2. Driveway shall be 6 inches thick Class 3000 concrete air entrained.
3. Broom finish surface with tooled joints and edges.
4. Depth of curb and low point shall be 1 inch max. from gutter flow line.

**DRIVEWAY WITH PLANTER STRIP**

	STANDARD PLANS	STR 06
	VERTICAL CURB DRIVEWAY APPROVED: <i>Stephan Jefferson</i> Director of Public Works/City Engineer	
REVISION: JAN 2003	NOT TO SCALE	BY: L.C.