



NOTES:

1. Curb and apron to be poured separately. Monolithic curb and apron is not allowed.
2. Driveway apron and sidewalk at driveway shall be 6" thick.
3. Broom finish surface with tooled joints and edges.
4. Concrete shall be Class 3000 air entrained concrete.
5. Driveway apron not to exceed width of driveway.
6. All expansion joints shall be full depth.

| | | |
|--|-----------------------------|--|
| <p>CITY OF MILL CREEK DEPARTMENT OF PUBLIC WORKS</p> | <p>STANDARD PLANS</p> | <p>STR 07</p> |
| | <p>ROLLED CURB DRIVEWAY</p> | <p>Approved: <i>Douglas Jefferson</i> Director of Public Works/City Engineer</p> |
| <p>Revision: JAN 2003</p> | <p>Not To Scale</p> | <p>By: L.C.</p> |