


LUMINAIRE:
 COBRA STYLE ROADWAY LUMINAIRE (BY GE)
 WITH PHOTOCELL, PROVIDED AND INSTALLED
 BY SNOHOMISH COUNTY PUD #1.
VOLTAGE: 240V
LAMP: 100W (RESIDENTIAL), 150W, 200W, 250W OR 400W
 (PROVIDED BY GE, PHILIPS OR SYLVANIA)
OPTICS: TYPE III, MEDIUM, CUTOFF

LUMINAIRE ARM:
 SP-6 (BY AMERON) - 2" SCHEDULE 40 SINGLE OR DOUBLE
 STEEL PIPE ARM WITH TOP MOUNT ASSEMBLY AND CAP.
COLOR: MILL CREEK BRONZE (CX)

POLE:
 DIRECT BURY, SYMMETRICALLY TAPERED, SPUN-CAST,
 PRESTRESSED CONCRETE POLE WITH EXPOSED
 AGGREGATE FINISH AND ARCHITECTURAL GLOSS COATING
 MANUFACTURED TO ASTM C-1089-97 (CENTRECON SERIES
 BY AMERON).
COLOR: NATURAL SAND BLASTED FINISH #313 BUFF

MER-7.5 (RESIDENTIAL)
 MER-9.0 (COLLECTORS/BUSINESS DISTRICT)
 MERX-10 (MAJOR ARTERIALS)

NOTES:
 1. THIS STANDARD SHALL APPLY TO LIGHTS INSTALLED
 EAST OF SR 527 (BOTHELL-EVERETT HWY).
 2. INSTALLATION OF ALL POLE COMPONENTS SHALL
 COMPLY WITH MANUFACTURER'S RECOMMENDATIONS.



* UNLESS APPROVED
 BY CITY ENGINEER



STANDARD PLAN
 M.C. STANDARD
 STREET LIGHT

LGT 077

APPROVED: *[Signature]*
 Director of Public Works/City Engineer

REVISION: MAR 2005 NOT TO SCALE BY: JC